## 2020 Water Audit

Certified validation Report							
Part A: Provi	ided by Validator						
Audit Information:							
Utility:	Beverly Hills	PWS ID:	1910156	_			
System Type:	Potable	Audit Period:	Calendar 2020	Utility Representation:	Vince Damasse		
Validation Call	Validation Call Date: 9/24/2021						
Validation Findings & Confirmation Statement:							
Key Audit Metrics:							
Data Validity Score: 69 Data Validity Band (Level): Band III (51-70)							
ILI: <u>2.46</u>	Real Loss:	38.90 (gal/conn	/day) Appar	rent Loss: 11.20 (gal/con	n/day)		
Certification Statement by Validator:							
This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water							
Code Section 10608.34. All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit.							
Validator Inf	ormation:						
Water Audit V	<b>/alidator:</b> Gre	eg Ripperger		Validator Qualifications:	Water Audit Validator Certificate		

Part B: Provided by U	Itility				
Water Supplier Name:	Beverly Hills	Water Supplier ID Number:	1910156	Water Audit Period:	Calendar 2020

## Water Audit & Water Loss Improvement Steps:

Utility to provide steps taken in preceding year to increase data validity, reduce real loss and apparent loss, as informed by the annual validated water audit:

Meter testing equipment that was purchased in preceding year was installed in City Ops yard. City staff received training and are now bench testing and replacing existing meters as needed. Worked with Finance staff to determine most efficient method to run financial data report to prorate customer meter reads, which are predominately read bi-monthly, so they better align with imported water purchase meter reads, which are recorded daily.

Certification Statement by Utility Executive:

This water loss audit report meets the requriemetns of California Code of rEgulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the mehtod adopted by the American Water Works Assoication, as contained in their manual, *Water Audit and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software.

Executive Name (Print):	Executive Position:	Signature:	Date:
Vince Damasse	Water Resources Manager	Vince Danone	9/29/21